

INTERIOR DIMENSION ARE TO THE BLOCK WALL AND NOT THE FURING STRIP
CONTRACTOR IS TO VERIFY BLOCK WALL HEIGHT W/ TRUSS COMPANY BEFORE CONSTRUCT

DRAWING STATUS

– FOR OFFICE USE ONLY –

D-2 DRYER VENT RECESS FRAMING DETAIL

SCALE: 1/2" = 1'-0"

©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

◇ ADDITIONAL FEATURES

SCHEDULES

SEE PAGE 6

CONSTRUCTION NOTES

1.) ALL WORK SHALL CONFORM TO FBCR 2004 AND ALL APPLICABLE LOCAL ORDINANCES.
2.) FOUNDATION DESIGN IS BASED ON A MINIMUM SOIL BEARING CAPACITY OF 2000 PSF.
3.) ALL CONCRETE SHALL HAVE A MINIMUM FC=3,000 PSI AT 28 DAYS.
4.) WELDED WIRE FABRIC (IF USED) SHALL CONFORM TO ASTM A-615 GRADE 60 AND A-305U
5.) FIBER REINFORCING SHALL CONFORM TO FBCR 2004 CODE REQUIREMENTS.
6.) ALL STRUCTURAL LUMBER SHALL HAVE A MINIMUM FB=1200 PSI SUB-CONTRACTOR SHALL VERIFY ALL DIMENSIONS.
7.) ALL VERT. REINF. SHALL TIE INTO FOUNDATION STEEL BY MEANS OF (1) #5 STD. HOOK (25" LAP MIN.) & TIE INTO CONT. BOND BEAM BY MEANS OF (1) #5 STD. HOOK (25" LAP MIN.)
8.) ANY LENGTHS OF WALL THAT ARE NO LESS THAN 1/2 THE CEILING HEIGHT & NOT CONTAINING OPENINGS GREATER THAN 144 SQ. INCHES TOTAL SHALL BE CONSIDERED TO BE A SHEARWALL. (SEE SSTD 1099 SECTION 205.5 EXT. MASONRY SHEARWALLS FOR REFERENCE.)
9.) UNLESS OTHERWISE NOTED, ANGLED WALLS ARE SET AT 45 DEGREES
10.) ALL MEDICINE CABINETS ARE RECESSED AND THE BOTTOMS ARE SET @ 52" A.F.F. (SIZE: 14" x 18")
11.) ALL #5 REINFORCING REBAR SHALL LAP 25" MIN.
12.) ALL STD. REINFORCING STEEL 90° HOOKS SHALL EXTEND AT LEAST 12-BAR DIAMETERS BEYOND THE BEND EXTENSION (LEG) = 10" FOR NO. 5 BARS, 14" FOR NO. 7 BARS, & 12" FOR NO. #3 BARS
13.) ROOF SHINGLES SHALL EXTEND PAST THE EAVES DRIP 1/2" MINIMUM 3/4" MAXIMUM
14.) CONSIDER ALL APPLIANCES ELECTRIC POWERED UNLESS OTHERWISE NOTED
15.) SEE FLOOR PLAN & FOUNDATION PAGES FOR CONNECTION & STRAPPING OF ALL LOAD BEARING WALLS
16.) RESISTANCE STRAPPING MANUFACTURERS MAY BE INTERCHANGED IF SO DESIRED PROVIDING CAPABLE LOADS ARE MAINTAINED OR INCREASED
17.) SEE MANUFACTURES'S ROUGH OPENING SCHEDULES ATTACHED TO VERIFY EGRESS COMPLIANCE
18.) SEE ATTACHED TRUSS PACKAGE FOR ALL TRUSS INFORMATION INCLUDING DESIGN LOADS OF STORAGE ROOMS IN ATTICS
19.) REINFORCING STEEL GRADE=60 (FY=60,000), ASTM A615-82 S1
20.) EXTERIOR WALL COVERINGS OTHER THAN CEMENTITIOUS FINISH OR PAINT SHALL NOT BE INSTALLED CLOSER THAN 6" TO GRADE IN COMPLIANCE W/ FBCR 703.2
21.) BUILDING WIND CLASSIFICATION COMPLIANCE AS PER R301.2(2)
22.) SEE TRUSS LAYOUT FOR ANY SUPPLEMENTAL TRUSS BRACING
23.) ANY REFERENCE SHOWN FOR A SCREEN ENCLOSURE SHALL BE PERMITTED INDEPENDANTLY BY A LICENSED ALUMINUM CONTRACTOR POSSIBLY TO BE CONSTRUCTED AT A FUTURE DATE
24.) ALL DUCTING FROM GARAGE SHALL BE CONSTRUCTED OF A MINIMUM No. 26. GAGE (0.48 MM) SHEET STEEL AND SHALL HAVE NO OPENINGS INTO THE GARAGE

H-1 HEADER DETAIL



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

HOME OWNER PLAN ACCEPTANCE

CUSTOMER SIGNATURE _____ DATE _____

CUSTOMER SIGNATURE _____ DATE _____

LINTEL SCHEDULE

THE LINTEL IDENTIFICATION TAGS SHOWN ON THIS PLAN COINCIDE WITH THE PRECAST & PRESTRESSED CONCRETE LINTEL CAPACITY TABLES DATED AUGUST 5, 2005 ENGINEERED BY DANSCO ENGINEERING, P.A. FOR MARION MASONRY MATERIALS, INC. SEE PAGE 6

K-1 DETAIL @ KITCHEN BAR TOP



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

D-4 TYPICAL EXT. DOOR JAMB ANCHORAGE DETAIL



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

WALL LEGEND

- WOOD FRAME WALL
- WOOD FRAME LOAD BEARING WALL
- INSULATED WOOD WALL
- 5V — SHEARWALL SEGMENT
- 9'-0" TOP OF BLOCK WALL
- 12'-0" TOP OF BLOCK WALL
- 15'-0" TOP OF BLOCK WALL

G-4 O.H.D. JAMB DETAIL



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

LEGEND

- ICE MAKER
- WALL MOUNT TUB SPOUT ONLY
- DECK MOUNTED TUB SPOUT
- SHOWER HEAD & WALL MOUNT TUB SPOUT
- SHOWER HEAD ONLY
- HOSE BIB
- (36) ADDITIONAL FEATURES REFERENCE
- ☆ BULL-NOSED CORNERS

LINTEL TABLE → S | 5.00 ← LINTEL LENGTH / 6'-8" ← BOTTOM OF LINTEL A.F.F.

A-10 SUSPENDED A/C UNIT



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

SQUARE FOOTAGES

LIVING	2,016	SQ. FT.
GARAGE	499	SQ. FT.
LANAI	233	SQ. FT.
ENTRY	149	SQ. FT.
TOTAL	2,897	SQ. FT.

ABBREVIATION KEY

A.B.	ANCOR BOLT
A.F.F.	ABOVE FINISHED FLOOR
ARCH.	ARCH TOP WINDOW
B.F.	BI-FOLD
B.O.H.	BOTTOM OF HEADER
CATH.	CATHEDERAL CEILING
CLG.	CEILING
COFF. CLG	COFFERED CEILING
D.	DRYER
D.W.	DISHWASHER
F.L.	FULL LIGHT
F.S.	FLOOR SAFE
C.S.D	GLASS SHOWER DOOR
H2O	WATER SUPPLY
M.C.	MEDICINE CABINET
MICR.	MICROWAVE
O.H.D	OVERHEAD DOOR(GARAGE DOOR)
REF.	REFREGERATOR
SEC. PAD	SECURITY PAD
S.D	SCREEN DOOR
S.G.D	SLIDING GLASS DOOR
S.H	SINGLE HUNG
S.H.F	SINGLE HUNG FRAME
S.L.	SIDE LIGHT
T.O.H	TOP OF HEADER
T.O.W	TOP OF WINDOW
T.W.H	TANKLESS WATER HEATER
W.	WASHER
W.H	WATER HEATER
W.S.	WALL SAFE
U.C.R.	UNDERCABINET REFREGERATOR
U.C.W.	UNDERCABINET WINE COOLER

ENGINEER'S NOTES

1.) DESIGN WIND LOAD = 110 M.P.H.
2.) THE ENGINEER SHALL SELECT TRUSS FASTENERS AND OTHER CONNECTORS BASED UPON THE TRUSS COMPANY'S ENGINEERED REACTIONS.
3.) THE SOIL BEARING CAPICITY SHALL BE = 2.0 K.S.F.
4.) LIVE LOADS USED = 20 P.S.F. DEAD LOADS ROOF = 10 P.S.F. ALL OTHER DEAD LOADS = ACTUAL WT. OF MATERIALS
5.) WIND IMPORTANCE FACTOR = 1.0
6.) BUILDING CATEGORY = "ENCLOSED"
7.) WIND EXPOSURE = "B"
8.) TOTALLY ENCLOSED INTERNAL PRESSURE COEFFICIENT = 0.18
9.) ALL OPENINGS IN EXTERIOR WALLS SHALL HAVE HORIZONTAL LOADING DESIGN AS DESCRIBED IN THE FOLLOWING TABLE R301.2(2). OF THE 2004 FLORIDA BUILDING CODE RESIDENTIAL. PAGE 3.4

TABLE R301.2(2)

ZONE	EFFECTIVE WIND AREA	BASIC WIND SPEED V (PSF)			
WALL	(SF)	100		110	
4	10.0	18.0	-19.5	21.8	-23.6
4	20.0	17.2	-18.7	20.8	-22.6
4	50.0	16.1	-17.8	19.5	-21.3
4	100.0	15.3	-16.8	18.5	-20.4
5	10.0	18.0	-24.1	21.8	-29.1
5	20.0	17.2	-22.5	20.8	-27.2
5	50.0	16.1	-20.3	19.5	-24.6
5	100.0	15.3	-18.7	18.5	-22.6

I HEREBY CERTIFY THAT I HAVE REVIEWED THIS STRUCTURE FOR INTEGRITY OF SHEARWALLS, ROOF DIAPHRAGMS, ETC., AND THAT THIS BUILDING COMPLIES WITH THE REQUIREMENTS OF THE 2004 FLORIDA BUILDING CODE RESIDENTIAL.

Harold W. Bontreau
PE. No. 49447
FL. Professional Engineer
Bontreau Gnn & Assoc., Inc.
1521 S.E 36th Ave. #2
1-352-624-9901
Certificate of Authorization 26364

Date: / /2006

G-12 GLASS BLOCK JAMB & SILL DETAIL (DRYWALL JAMB FINISH)



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

W-2 DETAIL @ PARTIONAL WALL



©Copyright I.P.C. Services, Inc. 2006 All Rights Reserved

HARBOR HILLS
COUNTRY CLUB

INITIAL PHASE CONSTRUCTION
IPC SERVICES, INC.
3250 SE 58TH AVENUE SUITE 1 OCALA, FLORIDA 34471
PHONE 352-732-4482 FAX 352-732-4485 WEB www.ipcs.biz
DRAFTING PERMITTING CONSULTING

CLOSING DATE: 07/18/06-MASTER BASE PLAN UPDATES
LOT
BLOCK
NEIGHBORHOOD
TYPICAL SCALE: 1/4" = 1'-0"

A NEW MODEL HOME FOR:
Florence Master Plan
MODEL CALL OUT: Model "B"
ELEVATION CALL OUT: Elevation "A"
DRAWN BY: I.P.C.Services
I.P.C. SERVICES JOB NUMBER 05158

PAGE NUMBER 1 OF 6

© Copyright Harbor Hills 2006 All Rights Reserved